



**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No:BBMP/MOH/MDP/PR/11/2024-25

Dated:20-04-2024

It is certified that an inspection team headed by DR. RAKESH.N MEDICAL OFFICER OF HEALTH & SREENIVASAPPA.N SR.HI(Name of Officers with designation) from BBMP HEALTH DEPARTMENT PHED inspected the VAGDEVI VILAS SCHOOL SY.NO.77/2,77/3B,77/4 AND 77/5 MUNNEKOLALU, MARTHAHALI POST, BENGALURU-560037(Name & Address of the school) on 19-04-2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no ULR NO: TC-125542400000167F dated:27-03-2024 of IADFAC LABORATORIES PVT LTD (PHED Lab) certified that the VAGDEVI VILAS SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till :20-4-2025

Signature with Seal:

Name : DR. RAKESH.N

Designation : MEDICAL OFFICER OF HEALTH


Name & Address of the Office/ Department : BBMP

To
VAGDEVI VILAS SCHOOL
SY.NO.77/2,77/3B,77/4 AND 77/5
MUNNEKOLALU, MARTHAHALI POST,
BENGALURU-560037
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For VAGDEVI VILAS SCHOOL

Chairman



"SEAL TRANSLATION"
MEDICAL OFFICER OF HEALTH
MAHADEVAPURA ZONE
BBMP

Annexure C

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No:BBMP/MOH/MDP/PR/11/2024-25

Dated:20-04-2024

It is certified that an inspection team headed by DR. RAKESH.N MEDICAL OFFICER OF HEALTH & SREENIVASAPPA.N SR.HI(Name of Officers with designation) from BBMP HEALTH DEPARTMENT PHED inspected the VAGDEVI VILAS SCHOOL SY.NO.77/2,77/3B,77/4 AND 77/5 MUNNEKOLALU, MARTHAHALI POST, BENGALURU-560037(Name & Address of the school) on 19-04-2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no ULR NO: TC-1255424000000167F dated:27-03-2024 of IADFAC LABORATORIES PVT LTD (PHED Lab)

certified that the VAGDEVI VILAS SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.
This certificate is valid till :20-4-2025

Signature with Seal:

[Handwritten Signature]
ಕರ್ನಾಟಕ ಸರ್ಕಾರ
ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಆರೋಗ್ಯ ಮತ್ತು ಕುಟುಂಬ ಕಲ್ಯಾಣ ಇಲಾಖೆ

Name : DR. RAKESH.N


Designation : MEDICAL OFFICER OF HEALTH

Name & Address of the Office/Department : BBMP

To
VAGDEVI VILAS SCHOOL
SY.NO.77/2,77/3B,77/4 AND 77/5
MUNNEKOLALU, MARTHAHALI POST,
BENGALURU-560037
(Name & Address of the Institution)

"SEAL TRANSLATION"
MEDICAL OFFICER OF HEALTH
MAHADEVAPURA ZONE
BENGALURU

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



For VAGDEVI VILAS SCHOOL
[Handwritten Signature]
Chairman

22 APR 2024

TESTED BY ME
[Handwritten Signature]
K.V. JAGANNATH REDDY, B.A., L.L.B.
ADVOCATE & NOTARY PUBLIC
GOVT. OF INDIA
No. 326, 2nd Cross, Behind Tulasi Theatre
Marathahalli, Bangalore - 560037

[Handwritten Signature]
Principal
VAGDEVI VILAS SCHOOL
Munnekolalu, Marathahalli Post
BENGALURU-560037



TC-12554



TEST REPORT

BOOKING NO. : 2416

REPORT NO. : 2416/2024-2025

ULR No. : TC-125542400000167F

NAME OF MANUFACTURER/PARTY :		VAGDEVI VILAS SCHOOL.	
		Sy. No. 77/2, 77/3B, 77/4 and 77/5	
		Munnekolalu, Marathahalli Post	
		BANGALORE - 560037 KARNATAKA	
1. MFG. LIC. NO.	NM	3. DATE	28/03/2024
2. REFERENCE NO.	NM	5. NAME OF SAMPLE	Drinking Water
4. DATE OF RECEIPT	28/03/2024		
6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)			
(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5Lx1 & 500ml	(F) DATE OF EXPIRY	NM
(G) PACKING	Sterile bottle & Plastic Can	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
I	BIOLOGICAL TESTING					
	Water					
1	Coliform	/100ml	Absent	Shall not be detectable in 100ml sample	No relaxation	IS 15185
2	E.coli	/100ml	Absent	Shall not be detectable in 100ml sample	No relaxation	IS 15185
II	CHEMICAL TESTING					
	Water					
1	Colour	HU	<1.0	5 Max	15 Max	IS 3025 (part 4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)
3	pH Value	-	6.8	6.5-8.5	No Relaxation	IS 3025 (PART 11)
4	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7 & 8) :2017
5	Turbidity	NTU	<1.0	1 Max	5 Max	IS 3025 (Part 10)
6	Total Dissolved Solids	mg/l	71.0	500 Max	2000 Max	IS 3025 (PART 16)
7	Aluminium (as Al)	mg/l	<0.02	0.03 Max	0.2 Max	IS 3025 (PART 55)
8	Anionic detergents (as MBAS)	mg/l	<0.1	0.2 Max	1.0 Max	IS 13428
9	Barium (as Ba)	mg/l	<0.5	0.7 Max	No Relaxation	IS 13428
10	Borates (as Boron)	mg/l	<0.1	0.5 Max	2.4 Max	IS 3025 (Part 57)
11	Calcium (as Ca)	mg/l	4.0	75 Max	200 Max	IS 3025 (Part 40)
12	Chloride (as Cl)	mg/l	11.0	250 Max	1000 Max	IS 3025 (Part 32)

Remarks : The Sample complies to the specifications as per the above tested parameters.

For IADFAC Laboratories Pvt. Ltd.

S. S. S. S.
 SHESNAGIRI B.
 (ID No. 196)
 FOOD ANALYST

U. K.
 Ulfas Kumbhar

AUTHORISED SIGNATORY

CONTD. ON NEXT PAGE.....

AUTHORISED SIGNATORY

Ulfas Kumbhar (ID No. 125)

Note : For IADFAC LABORATORIES PVT. LTD.

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without on explicit written permission from IADFAC Lab. P. Ltd
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month

For VAGDEVI VILAS SCHOOL

A. M. M.
 Chairman

U. K.
 Principal
 VAGDEVI VILAS SCHOOL
 Munnekolalu, Marathahalli Post
 BANGALURU-560 077



TEST REPORT

BOOKING NO. : 2416

REPORT NO. : 2416/2024-2025

ULR No. : TC-125542400000167F

NAME OF MANUFACTURER/PARTY : VAGDEVI VILAS SCHOOL.
 Sy. No. 77/2, 77/3B, 77/4 and 77/5
 Munnekolalu, Marathahalli Post
 BANGALORE - 560037 KARNATAKA

1. MFG. LIC. NO. NM
 2. REFERENCE NO. NM
 3. DATE 28/03/2024
 4. DATE OF RECEIPT 28/03/2024
 5. NAME OF SAMPLE Drinking Water

6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)

(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5Lx1 & 500ml	(F) DATE OF EXPIRY	NM
(G) PACKING	Sterile bottle & Plastic Can	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
13	Fluoride (as F)	mg/l	<0.1	1.0 Max	1.5 Max	IS 3025 (Part 60)
14	Free residual Chlorine	mg/l	<0.1	0.2 Min	1.0 Max	IS 3025 (PART 26)
15	Magnesium (as Mg)	mg/l	2.0	30 Max	100 Max	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
16	Nitrate (as NO3)	mg/l	3.79	45 Max	No Relaxation	IS 3025 (Part 34)
17	Phenolic Compounds (as C6H5OH)	mg/l	<0.001	0.001 Max	0.002 Max	IS 3025 (Part 43)
18	Sulphate (as SO4)	mg/l	7.92	200 Max	400 Max	IS 3025 (PART 24)
19	Sulphide (as H2S)	mg/l	<0.05	0.05 Max	No Relaxation	IS 3025 (Part 29)
20	Total Alkalinity as calcium carbonate	mg/l	15.0	200 Max	600 Max	IS 3025 (PART 23)
21	Total Hardness (as CaCO3)	mg/l	17.0	200 Max	600 Max	IS 3025 (PART 21)
22	Cyanide (as CN)	mg/l	<0.01	0.05 Max	No Relaxation	IS 3025 : Part 27
23	Polychlorinated Biphenyle (PCB)					
a	2,6-Di chloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 6431C 24th edition
b	2,4,4 Tricholoro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 6431C 24th edition
c	2,2,5,5-Tetrachloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 6431C 24th edition
d	2,2,4,4,5,5 Hexacholoro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 6431C 24th edition
e	2,2,3,4,4,5,-Hexa chloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 6431C 24th edition
f	2,2,3,4,4,5,5 Heptacholoro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 6431C 24th edition

Remarks : The Sample complies to the specifications as per the above tested parameters.

For IADFAC Laboratories Pvt. Ltd.

CONTD. ON NEXT PAGE.....

AUTHORISED SIGNATORY

Ullas Kumbhar (ID No. 125)


Note :

- The results listed, refer only to the samples analysed & applicable parameters. Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab. P. Ltd
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed after one month.

K. Gowd
 Chairman

Ullas Kumbhar
 Principal

VAGDEVI VILAS SCHOOL
 Munnekolalu, Marathahalli Post
 BANGALORE - 560 037



TC-12554



TEST REPORT

BOOKING NO. : 2416

REPORT NO. : 2416/2024-2025


ULR No. : TC-125542400000167F

NAME OF MANUFACTURER/PARTY :		VAGDEVI VILAS SCHOOL.	
		Sy. No. 77/2, 77/3B, 77/4 and 77/5	
		Munnekolalu, Marathahalli Post	
		BANGALORE - 560037 KARNATAKA	
1. MFG. LIC. NO.	NM	3. DATE	28/03/2024
2. REFERENCE NO.	NM	5. NAME OF SAMPLE	Drinking Water
4. DATE OF RECEIPT	28/03/2024		
6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)			
(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5Lx1 & 500ml	(F) DATE OF EXPIRY	NM
(G) PACKING	Sterile bottle & Plastic Can	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
24	Poly Nuclear Aromatic Hydrocarbons (PAH)					
a	Anthracene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th Edition
b	Phenanthrene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
c	Benzo (a)anthracene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
d	Benzo (b) fluoranthene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
e	Benzo (g,h,i) pyrene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
f	Benzo (g,h,i) Perylene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
g	Fluoranthene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
h	Indeno (1,2,3-c,d) pyrene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
i	Acenaphthene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
j	Acenaphthylene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
k	Fluorene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
l	Pyrene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
m	Dibenzo(a,h) anthracene	mg/l	<0.00001	0.0001 Max	No Relaxation	APHA 6440C 24th edition
25	Mineral Oil	mg/l	<0.5	0.5 Max	No Relaxation	IS 3025 Part 39
26	Copper (as Cu)	mg/l	0.01	0.05 Max	1.5 Max	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
27	Iron (as Fe)	mg/l	<0.05	0.3 Max	No Relaxation	IS 3025 : Part 53
28	Manganese (as Mn)	mg/l	<0.05	0.1 Max	0.3 Max	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022

Remarks : The Sample complies to the specifications as per the above tested parameters. For IADFAC Laboratories Pvt. Ltd.



AUTHORISED SIGNATORY
 Ullas Kumbhar (ID No. 125)

CONTD. ON NEXT PAGE.....

Note :

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without on explicit written permission from IADFAC Lab. P. Ltd
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.


 Chairman


 Principal
 VAGDEVI VILAS SCHOOL
 Munnekolalu, Marathahalli Post
 BANGALORE - 560037



TEST REPORT

BOOKING NO. : 2416

REPORT NO. : 2416/2024-2025

ULR No. : TC-125542400000167F

NAME OF MANUFACTURER/PARTY :		VAGDEVI VILAS SCHOOL.	
		Sy. No. 77/2, 77/3B, 77/4 and 77/5	
		Munnekolalu, Marathahalli Post	
		BANGALORE - 560037 KARNATAKA	
1. MFG. LIC. NO.	NM	3. DATE	28/03/2024
2. REFERENCE NO.	NM	5. NAME OF SAMPLE	Drinking Water
4. DATE OF RECEIPT	28/03/2024		
6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)			
(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5Lx1 & 500ml	(F) DATE OF EXPIRY	NM
(G) PACKING	Sterile bottle & Plastic Can	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
29	Selenium (as Se)	mg/l	<0.005	0.01 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
30	Silver (as Ag)	mg/l	<0.005	0.1 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
31	Zinc (as Zn)	mg/l	<0.005	5.0 Max	15 Max	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
32	Cadmium (as Cd)	mg/l	<0.005	0.003 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
33	Lead (as Pb)	mg/l	<0.005	0.01 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
34	Mercury (as Hg)	mg/l	<0.005	0.001 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
35	Nickel (as Ni)	mg/l	<0.005	0.02 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
36	Total Arsenic (as As)	mg/l	<0.005	0.01 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
37	Total Chromium (as Cr)	mg/l	0.02	0.05 Max	No Relaxation	IADFAC/V/C09, 2022 ,Issue no-01 ,Issue date 07.02.2022
	Pesticide residues					
1	Alachlor	µg/l	<0.01	20 Max	No Relaxation	APHA 6630D 24th edition:

Remarks : The Sample complies to the specifications as per the above tested parameters.

For IADFAC Laboratories Pvt. Ltd.

CONTD. ON NEXT PAGE.....

AUTHORISED SIGNATORY

Ullas Kumbhar (ID No. 125)

Note :

- The results listed, refer only to the samples analysed & applicable parameters. Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab. P. Ltd
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed after one month.

[Signature]
Chairman

[Signature]
Principal
VAGDEVI VILAS SCHOOL
Munnekolalu, Marathahalli Post
BANGALURU-560 037



TC-12554



TEST REPORT

BOOKING NO. : 2416

REPORT NO. : 2416/2024-2025

ULR No. : TC-125542400000167F

NAME OF MANUFACTURER/PARTY :		VAGDEVI VILAS SCHOOL.	
		Sy. No. 77/2, 77/3B, 77/4 and 77/5	
		Munnkolalu, Marathahalli Post	
		BANGALORE - 560037 KARNATAKA	
1. MFG. LIC. NO.	NM	3. DATE	28/03/2024
2. REFERENCE NO.	NM	5. NAME OF SAMPLE	Drinking Water
4. DATE OF RECEIPT	28/03/2024		
6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)			
(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5Lx1 & 500ml	(F) DATE OF EXPIRY	NM
(G) PACKING	Sterile bottle & Plastic Can	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
2	Aldrin/Dieldrin	µg/l	<0.01	0.03 Max	No Relaxation	APHA 6630D 24th edition:
3	Alpha HCH	µg/l	<0.01	0.01 Max	No Relaxation	APHA 6630D 24th edition:
4	Beta HCH	µg/l	<0.01	0.04 Max	No Relaxation	APHA 6330 D 24th edition:
5	Gamma-HCH	µg/l	<0.01	2 Max	No Relaxation	APHA 6330 D 24th edition:
6	Butachlor	µg/l	<0.01	125 Max	No Relaxation	EPA 8141 B
7	Chlorpyrifos	µg/l	<0.01	30 Max	No Relaxation	EPA 8141 B
8	Delta HCH	µg/l	<0.01	0.04 Max	No Relaxation	APHA 6630D 24th edition:
9	2,4-Dichlorophenoxyacetic acid	µg/l	<0.025	30 Max	No Relaxation	IADFAC/V/C06, 2018: Issue No:01, Issue Date:06.09.2018
10	DDT					
a	o,p DDE	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
b	o,p-DDD	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
c	o,p-DDT	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
d	p,p-DDE	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
e	p,p-DDD	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
f	p,p-DDT	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
11	Endosulfan					
a	Alpha Endosulfan	µg/l	<0.01	0.4 Max	No Relaxation	APHA6630D 24th edition:
b	Beta Endosulfan	µg/l	<0.01	0.4 Max	No Relaxation	APHA6630D 24th edition:

Remarks : The Sample complies to the specifications as per the above tested parameters.

For IADFAC Laboratories Pvt. Ltd.

CONTD. ON NEXT PAGE.....

Authorised Signatory
 Vilas Kumbhar (ID No. 125)

Note :

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab. P. Ltd
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

For VAGDEVI VILAS SCHOOL

K. Kulkarni
 Chairman

V. Kulkarni
 Principal

VAGDEVI VILAS SCHOOL
 Munnkolalu, Marathahalli Post
 BANGALURU-560 037



TC-12554



TEST REPORT

BOOKING NO. : 2416

REPORT NO. : 2416/2024-2025

ULR No. : TC-125542400000167F

NAME OF MANUFACTURER/PARTY : VAGDEVI VILAS SCHOOL.
 Sy. No. 77/2, 77/3B, 77/4 and 77/5
 Munnekolalu, Marathahalli Post
 BANGALORE - 560037 KARNATAKA

1. MFG. LIC. NO. NM
 2. REFERENCE NO. NM
 3. DATE 28/03/2024
 4. DATE OF RECEIPT 28/03/2024
 5. NAME OF SAMPLE Drinking Water

6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)

(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5Lx1 & 500ml	(F) DATE OF EXPIRY	NM
(G) PACKING	Sterile bottle & Plastic Can	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
c	Endosulfan sulphate	µg/l	<0.01	0.4 Max	No Relaxation	APHA6630D 24th edition: EPA 8141B IADFAC/IC07R Issue No.02, Issue Date:26/06/2028 EPA 8141B EPA 8141B EPA 8141B EPA 8141B
12	Ethion	µg/l	<0.01	3 Max	No Relaxation	
13	Isoproturon	µg/l	<0.01	9 Max	No Relaxation	
14	Malathion	µg/l	<0.01	190 Max	No Relaxation	
15	Monocrotophos	µg/l	<0.025	1 Max	No Relaxation	
16	Phorate	µg/l	<0.01	2 Max	No Relaxation	
17	Methyl Parathion	µg/l	<0.01	0.3 Max	No Relaxation	

Remarks : The Sample complies to the specifications as per the above tested parameters.

For IADFAC Laboratories Pvt. Ltd.

End Of Report

(Signature)
 Authorised Signatory
AUTHORISED SIGNATORY
 Ullas Kumbhar (ID No. 125)

- Note :**
- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
 - Total liability of our institute is limited to the invoiced amount.
 - The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab. P. Ltd
 - Sample drawn and submitted by the party for analysis unless otherwise stated.
 - Analysed Food samples are destroyed after one month.

(Signature)
 Chairman

(Signature)
 Principal
 VAGDEVI VILAS SCHOOL
 Munnekolalu, Marathahalli Post
 BANGALORE-560 037



TEST REPORT

BOOKING NO. : 2416A
 REPORT NO. : 2416A/2024-2025

NAME OF MANUFACTURER/PARTY :		VAGDEVI VILAS SCHOOL.	
		Sy. No. 77/2, 77/3B, 77/4 and 77/5	
		Munnekolalu, Marathahalli Post	
		BANGALORE - 560037 KARNATAKA	
1. MFG. LIC. NO.	NM	3. DATE	28/03/2024
2. REFERENCE NO.	NM	5. NAME OF SAMPLE	Drinking Water
4. DATE OF RECEIPT	28/03/2024		
6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)			
(A) MANUFACTURER NAME	NM	(B) BATCH NO.	NM
(C) BATCH SIZE	NM	(D) DATE OF MFG.	NM
(E) SAMPLE QUANTITY	5L	(F) DATE OF EXPIRY	NM
(G) PACKING	Plastic cane	(H) STARTING DATE	28/03/2024
(I) SEALED	Sealed	(J) ENDING DATE :	08/04/2024
(K) BRAND NAME	NM	(L) SAMPLING PROTOCOL	NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION	27/03/2024	(N) REPORT GEN. DATE	08/04/2024


Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
I	CHEMICAL TESTING					
	RESIDUES IN Water					
1	Ammonia (as total ammonia- N)	mg/l	<0.1	0.5 Max	No Relaxation	IS 3025 (Part-34) : 1988
2	Chloramines (as Cl ₂)	mg/l	<0.01	4.0 Max	No Relaxation	IS 3025 (Part-26) : 1986
3	Molybdenum (as Mo)	mg/l	<0.005	0.07 Max	No Relaxation	IADFAC/IC09
4	Pesticide residues					
a	Atrazine	µg/l	<0.01	2 Max	No Relaxation	EPA 8141B
5	Trihalomethanes					
a	Bromoform	mg/l	<0.01	0.1 Max	No Relaxation	APHA 4th Edition Chapter no 6232
b	Dibromochloro methane	mg/l	<0.01	0.1 Max	No Relaxation	APHA 4th Edition Chapter no 6232
c	Bromodichloro Methane	mg/l	<0.01	0.06 Max	No Relaxation	APHA 4th Edition Chapter no 6232
d	Chloroform	mg/l	<0.01	0.2 Max	No Relaxation	APHA 4th Edition Chapter no 6232

For IADFAC Laboratories Pvt. Ltd.

Remarks : The Sample complies to the specifications as per the above tested parameters.

End Of Report



 Authorised Signatory
V. K. Kulkarni (ID No. 125)

Note :

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab. P. Ltd
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

For VAGDEVI VILAS SCHOOL


 Chairman


 PRINCIPAL
 VAGDEVI VILAS SCHOOL
 Munnekolalu, Marathahalli Post
 BANGALURU-560 037